



# ELIGIBILITY CHECKLIST

## Expedited PV Permitting for One and Two Family Dwellings Only

(Please answer the following questions to determine eligibility)

### GENERAL REQUIREMENTS

1. System size of 10kW AC CEC rating or less  Y  N
2. The solar array is roof-mounted on a "one or two family dwelling unit" or residential accessory structure?  Y  N
3. The solar panel/module arrays does not exceed the maximum legal building height?  Y  N
4. The solar system is utility interactive and without battery storage?  Y  N
5. A [Building Permit Application](#) is completed and attached?  Y  N
6. Do you have Planning Department approval for your project? (Stamped Title Sheet)  Y  N

### ELECTRICAL REQUIREMENTS

1. No more than four PV module strings are connected to each Maximum Power Point Tracking (MPPT) input where source circuit fusing is included in the inverter?  Y  N
  - a) *No more than two strings per MPPT input where source circuits fusing is not included?*  Y  N
  - b) *Fuses (if needed) are rated to the series fuse rating of the PV module?*  Y  N
  - c) *No more than one non-inverter integrated DC combiner is utilized?*  Y  N
2. For central inverter systems: No more than two inverters are utilized?  Y  N
3. The PV system is interconnected to a single-phase AC service (120/220Vac) with a bus bar rating of 225A or Less?  Y  N
4. The PV system is connected to the load side of the utility distribution equipment?  Y  N
5. A complete solar plan or "Solar PV Simplified" and supporting documentation is completed and attached?  Y  N

### STRUCTURAL REQUIREMENTS (EITHER / OR)

1. A completed Structural Criteria and supporting documentation is attached (if required)?  Y  N
5. If "No," has a California licensed design professional provided a structural design or approval?  Y  N

### FIRE SAFETY REQUIREMENTS

1. Clear access pathways are provided?  Y  N
2. Fire classification solar system compliance is provided?  Y  N
3. All required markings and labels are provide?  Y  N
4. A diagram of the roof layout of all panels, modules, clear access pathways and approximate location of electrical disconnecting means and roof access points is completed and attached?  Y  N

#### Notes:

1. *These criteria are intended for expedited solar permitting process.*
2. *If any items are checked NO revise design to fit within Eligibility Checklist, otherwise permit application may go through standard plan review process.*