



NOTE

1. CONDUIT, CONDUCTORS AND PULLBOXES SHALL BE PER THE PLAN.
2. THIS DETAIL IS SCHEMATIC. FIELD CONDITIONS MAY REQUIRE VARIED CONFIGURATIONS.
3. SIGNAL AND SIC CONDUCTORS MUST BE ISOLATED FROM EACH OTHER.

DATE: <u>SEPT. 2001</u>	<h1>SIC ISOLATION DETAIL</h1>	SCALE: <u>NONE</u>
Signature on File CITY ENGINEER		DEPARTMENT OF PUBLIC WORKS CITY OF PALM DESERT