



NOTES:

1. COMBINED THICKNESS OF BASE AND SURFACE TO BE DETERMINED BY R-VALUE TEST. T.I. = 5.0
2. MINIMUM PAVING THICKNESS TO BE 3" ASPHALT CONCRETE, MIN. CLASS 2 AGG. BASE THICKNESS=4"
3. ALL CURB AND GUTTER TO BE TYPE 1 (8" CURB FACE), UNLESS OTHERWISE SPECIFIED.

\* 4. 50' APPLICABLE TO CUL-DE-SAC STREET ONLY, SUBJECT TO APPROVAL BY THE CITY ENGINEER.

DATE: SEPT. 2001

Signature on File  
CITY ENGINEER

# RESIDENTIAL STREET

DEPARTMENT OF PUBLIC WORKS

CITY OF PALM DESERT

SCALE: NONE

STD DRAWING NO.

307