



NOTES:

1. COMBINED THICKNESS OF BASE AND SURFACE TO BE DETERMINED BY R-VALUE TEST. T.I. = 7.0
2. MINIMUM PAVING THICKNESS TO BE 4 1/2" ASPHALT CONCRETE, MIN. CLASS 2 AGG. BASE THICKNESS=7"
3. ALL CURB AND GUTTER TO BE TYPE I (8" CURB FACE), UNLESS OTHERWISE SPECIFIED.
- \* 4. SIDEWALK MAY BE EITHER MEANDERING OR BEHIND CURB FACE WITH 6' OR 8' WIDTHS PER CONDITIONS OF APPROVAL.
- \*\* 5. ONLY BY SPECIAL REQUIREMENT OF PLANNING COMMISSION.

DATE: SEPT. 2001

# SECONDARY ROADWAY

SCALE: NONE

Signature on File  
CITY ENGINEER

DEPARTMENT OF PUBLIC WORKS

CITY OF PALM DESERT

STD DRAWING NO.

305