



NOTES:

1. COMBINED THICKNESS OF BASE AND SUFRACE TO BE DETERMINED BY R-VALUE TEST. T.I. = 8.5
2. MINIMUM PAVING THICKNESS TO BE 5" ASPHALT CONCRETE, MIN. CLASS 2 AGG. BASE THICKNESS=10"
3. ALL CURB AND GUTTER TO BE TYPE I (8" CURB FACE), UNLESS OTHERWISE SPECIFIED.
- \* 4. SIDEWALK MAY BE EITHER MEANDERING OR BEHIND CURB FACE WITH 6' OR 8' WIDTHS PER CONDITIONS OF APPROVAL.
- \*\* 5. ONLY BY SPECIAL REQUIREMENT OF PLANNING COMMISSION.

DATE: SEPT. 2001

\_\_\_\_\_  
CITY ENGINEER

**MAJOR THOROUGHFARE**

DEPARTMENT OF PUBLIC WORKS      CITY OF PALM DESERT

SCALE: NONE

STD DRAWING NO.  
**303**