



NOTES:

- 1. COMBINED THICKNESS OF BASE AND SURFACE TO BE DETERMINED BY R-VALUE TEST. T.I. = 8.5
- 2. MINIMUM PAVING THICKNESS TO BE 5 1/2" ASPHALT CONCRETE, MIN. CLASS 2 AGG. BASE THICKNESS=10"
- 3. ALL CURB AND GUTTER TO BE TYPE I (8" CURB FACE), UNLESS OTHERWISE SPECIFIED.
- * 4. SIDEWALK MAY BE EITHER MEANDERING OR BEHIND CURB FACE WITH 6' OR 8' WIDTHS PER CONDITIONS OF APPROVAL.
- ** 5. ONLY BY SPECIAL REQUIREMENT OF PLANNING COMMISSION.

DATE: SEPT. 2001

Signature on File
CITY ENGINEER

ARTERIAL STREET - 134' R/W

DEPARTMENT OF PUBLIC WORKS CITY OF PALM DESERT

SCALE: NONE

STD DRAWING NO.
302B