



- NOTE 1: SAWCUT AND REMOVE CROSS HATCHED PORTION OF CURB SECTION.
- NOTE 2: CLASS 560-C-3250 CONCRETE SHALL BE USED TO RECONSTRUCT THE CURB SECTION.
- NOTE 3: WHEN CURB FACE ELEVATION IS LESS THAN 8" HIGH, THE FLOW LINE OF THE PIPE SHALL BE AT LEAST 1/2" ABOVE THE ELEVATION OF THE FLOW LINE OF THE GUTTER, AND THE PIPE SHOULD BE 3" IN DIAMETER.
- NOTE 4: A MINIMUM SEPARATION OF TEN FEET (10') IS REQUIRED BETWEEN ADJACENT DRAINS ON THE SAME PROPERTY.
- NOTE 5: WHEN GREATER CAPACITY IS REQUIRED, CITY OF PALM DESERT STANDARD NUMBER 200 SHALL BE CONSTRUCTED.

CASE A – SAW CUT OPTION

CORE DRILLING IN LIEU OF SAW CUT OPTION IS PERMITTED PROVIDED:

- (1) INVERT ELEVATION OF THE CORE SHALL BE AT LEAST 1/2" ABOVE THE FLOW LINE ELEVATION.
- (2) CORE DIAMETER SHALL NOT EXCEED 50% OF THE CURB FACE DIMENSION.
- (3) A MINIMUM SEPARATION OF TEN FEET (10') IS REQUIRED BETWEEN ADJACENT DRAINS ON THE SAME PROPERTY.
- (4) WHEN GREATER CAPACITY IS REQUIRED, CITY OF PALM DESERT STANDARD NUMBER 200 SHALL BE CONSTRUCTED.

CASE B – CORE DRILL OPTION

DATE: SEPT. 2001	CURB DRAIN	SCALE: NONE
Signature on File CITY ENGINEER	CASE A – CASE B	STD DRAWING NO.
	DEPARTMENT OF PUBLIC WORKS	CITY OF PALM DESERT
		200-1